

Air Driven Odor Control Systems

HLDA1500

Operation & Maintenance

*Replace Filter
as needed
20"x 20"x1"*



*Prime and Set Pump
for 1/2 Gallon per day.
Set pump at 30% Speed
and 30% Stroke
P121-353SI*



*Connect unit to Power:
460/3/60, 20.5 Amps Service
4 wire 10 Gauge SO*

